

## **Ontario Drinking-Water Systems Regulation O. Reg. 170-03 (s)11**

### **Stayner 2019 Annual Report**

Drinking-Water System Number: 220001138  
Drinking-Water System Name: Stayner Drinking Water System  
Drinking-Water System Owner: The Corporation of the Township of Clearview  
Drinking-Water System Category: Large Municipal Residential  
Period being reported: January – December 2019

This Drinking-Water System does not serve more than 10,000 people.

This annual report is available to the public at no charge on the Clearview website at [www.clearview.ca](http://www.clearview.ca)

The Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection at the Clearview Municipal Office 217 Gideon Street, Stayner and at the Clearview public works building at 5833 County Road 96, Stayner.

No other Drinking Water Systems receive their drinking water from this system.

This annual report is available free of charge on our web-site, and at the locations listed above. Notice of the report availability is provided on the Clearview web-site and on digital signboards throughout Clearview. Report availability is also advertised in the local newspaper.

Description of the system:

The water source for this system is four groundwater source wells. Disinfection is provided with sodium hypochlorite. ClearHib5 (blended phosphates) is used to sequester iron. Water storage is in two glass-lined steel tanks with a total capacity of 7100 m<sup>3</sup>. There are approximately 1700 active service connections. There are 222 hydrants throughout the system for fire protection.

Chemicals used for treatment include 12% Sodium Hypochlorite and ClearHib 5 blended phosphates.

Significant expenses incurred to install, repair, or replace equipment:

Replaced Free Chlorine Analyzer at Stayner Well # 1 Pumphouse - \$5,532

Radio Communication Equipment Upgrades / Replacements - \$30,000

County Road 42 Transmission Watermain Replacement (2019 portion) - \$4,220,000

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Oct. 30, 2019	Total Coliform	1	Count / 100 mL	Resample	Oct. 30, 2019
Nov. 7, 2019	Total Coliform	93	Count / 100 ml	Flushed watermain Resample	Nov. 7, 2019

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

Type of Sample	Number of Samples	Range of E.coli Or Fecal Results (min #)- (max #) CFU/100 mL	Range of Total Coliform Results (min #)- (max #) CFU/100 mL	Number of HPC Samples	Range of HPC Results (min #)- (max #) CFU/100 mL
Raw – Well # 1	53	0 – 0	0 – 3	0	NA
Raw – Well # 2	53	0 – 0	0 – 0	0	NA
Raw – Well # 3	53	0 – 0	0 – 0	0	NA
Raw – Well # 4	53	0 – 0	0 – 1	0	NA
Treated – Well # 1	53	0 – 0	0 – 1	53	<10 – 780
Treated – Well # 2/4	53	0 – 0	0 – 0	53	<10 – 320
Treated – Well # 3	53	0 – 0	0 – 0	53	<10 – 130
Distribution	212	0 – 0	0 – 0	53	<10 - 50

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

Parameter	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
System Chlorine	416	0.26 – 1.32	mg/L
Chlorine			
Well # 1	8760	0.31 – 2.27	mg/L
Well # 2/4	8760	0.39 – 2.61	mg/L
Well # 3	8760	0.56 – 1.56	mg/L
Turbidity			
Raw – Well # 1	12	0.77 – 1.63	NTU
Raw – Well # 2	12	0.71 – 3.28	NTU
Raw – Well # 3	12	0.76 – 1.78	NTU
Raw – Well # 4	12	0.83 – 3.54	NTU

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of lead testing under Schedule 15.1 during this reporting period (applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	0	NA	mg/L	NA
Distribution	6	0.00007 – 0.00043	mg/L	NA

Samples required under Schedule 13

Parameter	Last Date Sampled	Result	Unit of Measure
THM's (annual running average)	10/22/2019	0.0088	mg/L
HAA's (annual running average)	10/22/2019	<0.0053	mg/L
Nitrate – Well # 1	10/22/2019	0.3	mg/L
Nitrate – Well # 2/4	10/22/2019	8.1	mg/L
Nitrate – Well # 3	10/22/2019	0.2	mg/L
Nitrite – Well # 1	10/22/2019	<0.1	mg/L
Nitrite – Well # 2/4	10/22/2019	<0.1	mg/L
Nitrite – Well # 3	10/22/2019	<0.1	mg/L
Sodium – Well # 1	09/24/2019	9.9	mg/L
Sodium – Well # 2	09/24/2019	7.1	mg/L
Sodium – Well # 3	09/24/2019	7.3	mg/L
Fluoride – Well # 1	07/18/2017	<0.1	mg/L
Fluoride – Well # 2/4	07/18/2017	<0.1	mg/L
Fluoride – Well # 3	07/18/2017	<0.1	mg/L

The most recent sample results of Inorganic parameters tested during this reporting period.

– Appendix – A

The most recent sample results of Organic parameters sampled during this reporting period.

– Appendix – B

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. N/A

**APPENDIX A**  
**INORGANIC PARAMETERS**  
**(SCHEDULE 23)**

C.O.C.: DWC191203S23D

REPORT No. B19-39044

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 03-Dec-19

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 12-Dec-19

P.O. NUMBER: ST Schedule 23

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

<b>Client I.D.:</b>	ST # 1 Treated	ST #2 & 4 Treated	<b>ODWS</b>	
<b>Sample I.D.:</b>	B19-39044-1	B19-39044-2	<b>Objective</b>	<b>Type of Objective</b>
<b>Date Collected:</b>	03-Dec-19	03-Dec-19		

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Antimony	mg/L	0.0001	EPA 200.8	06-Dec-19/O	< 0.0001	< 0.0001	0.006,0.006	IMAC,MAC
Arsenic	mg/L	0.0001	EPA 200.8	06-Dec-19/O	0.0005	0.0002	0.025,0.01	IMAC,MAC
Barium	mg/L	0.001	SM 3120	11-Dec-19/O	0.075	0.042	1	MAC
Boron	mg/L	0.005	SM 3120	11-Dec-19/O	0.018	0.011	5,5	IMAC,MAC
Cadmium	mg/L	0.000015	EPA 200.8	06-Dec-19/O	< 0.000015	< 0.000015	0.005	MAC
Chromium	mg/L	0.002	SM 3120	11-Dec-19/O	< 0.002	< 0.002	0.05	MAC
Mercury	mg/L	0.00002	SM 3112 B	06-Dec-19/O	< 0.00002	< 0.00002	0.001	MAC
Selenium	mg/L	0.001	EPA 200.8	06-Dec-19/O	< 0.001	< 0.001	0.05	MAC
Uranium	mg/L	0.00005	EPA 200.8	06-Dec-19/O	0.00064	0.00080	0.02	MAC
Free Chlorine	mg/L		n/a	03-Dec-19/B	1.10	1.06		

1 Free chlorine results provided by client.

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: DWC191203S23D

REPORT No. B19-39044

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 03-Dec-19

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 12-Dec-19

P.O. NUMBER: ST Schedule 23

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

<b>Client I.D.:</b>	ST # 3 Treated	<b>ODWS</b>	<b>Objective</b>	<b>Type of Objective</b>
<b>Sample I.D.:</b>	B19-39044-3			
<b>Date Collected:</b>	03-Dec-19			

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Antimony	mg/L	0.0001	EPA 200.8	06-Dec-19/O	< 0.0001		0.006,0.006	IMAC,MAC
Arsenic	mg/L	0.0001	EPA 200.8	06-Dec-19/O	0.0005		0.025,0.01	IMAC,MAC
Barium	mg/L	0.001	SM 3120	11-Dec-19/O	0.067		1	MAC
Boron	mg/L	0.005	SM 3120	11-Dec-19/O	0.017		5,5	IMAC,MAC
Cadmium	mg/L	0.000015	EPA 200.8	06-Dec-19/O	< 0.000015		0.005	MAC
Chromium	mg/L	0.002	SM 3120	11-Dec-19/O	< 0.002		0.05	MAC
Mercury	mg/L	0.00002	SM 3112 B	06-Dec-19/O	< 0.00002		0.001	MAC
Selenium	mg/L	0.001	EPA 200.8	06-Dec-19/O	< 0.001		0.05	MAC
Uranium	mg/L	0.00005	EPA 200.8	06-Dec-19/O	0.00053		0.02	MAC
Free Chlorine	mg/L		n/a	03-Dec-19/B	1.13			

1 Free chlorine results provided by client.

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

**APPENDIX B**  
**ORGANIC PARAMETERS**  
**(SCHEDULE 24)**

C.O.C.: DWC180213S

REPORT No. B18-03847

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 13-Feb-18

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 05-Mar-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

<b>Client I.D.:</b>	ST # 1 Treated	ST # 2 Treated	<b>ODWS</b>	
<b>Sample I.D.:</b>	B18-03847-1	B18-03847-2	<b>Objective</b>	<b>Type of Objective</b>
<b>Date Collected:</b>	12-Feb-18	12-Feb-18		

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Benzene	µg/L	0.5	EPA 8260	14-Feb-18/O	< 0.5	< 0.5	1	MAC
Carbon Tetrachloride	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2	< 0.2	2	MAC
Dichlorobenzene,1,2-	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1	< 0.1	3,200	AO,MAC
Dichlorobenzene,1,4-	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2	< 0.2	1,5	AO,MAC
Dichloroethane,1,2-	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1	< 0.1	5	IMAC
Dichloroethene, 1,1-	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1	< 0.1	14	MAC
Dichloromethane (Methylene Chloride)	µg/L	0.3	EPA 8260	14-Feb-18/O	< 0.3	< 0.3	50	MAC
Monochlorobenzene (Chlorobenzene)	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2	< 0.2	80	MAC
Tetrachloroethylene	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2	< 0.2	10	MAC
Trichloroethylene	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1	< 0.1	5	MAC
Vinyl Chloride	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2	< 0.2	1	MAC
Alachlor	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3	< 0.3	5	IMAC
Atrazine + Metabolites	µg/L	0.5	Calc.	02-Mar-18/K	< 0.5	< 0.5	5	IMAC
Azinphos-methyl	µg/L	1	EPA 8270	02-Mar-18/K	< 1	< 1	20	MAC
Benzo(a)pyrene	µg/L	0.005	EPA 8270	02-Mar-18/K	< 0.005	< 0.005	0.01	MAC
Bromoxynil	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3	< 0.3	5	IMAC
Carbaryl	µg/L	3	EPA 8270	02-Mar-18/K	< 3	< 3	90	MAC
Carbofuran	µg/L	1	EPA 8270	02-Mar-18/K	< 1	< 1	90	MAC
Chlorpyrifos	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5	< 0.5	90	MAC
Diazinon	µg/L	1	EPA 8270	02-Mar-18/K	< 1	< 1	20	MAC
Dicamba	µg/L	5	EPA 8270	02-Mar-18/K	< 5	< 5	120	MAC
Dichlorophenol, 2,4-	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1	< 0.1	0.3,900	AO,MAC

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: DW180213S

REPORT No. B18-03847

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 13-Feb-18

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 05-Mar-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

<b>Client I.D.:</b>	ST # 1 Treated	ST # 2 Treated	<b>ODWS</b>	
<b>Sample I.D.:</b>	B18-03847-1	B18-03847-2	<b>Objective</b>	<b>Type of Objective</b>
<b>Date Collected:</b>	12-Feb-18	12-Feb-18		

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	µg/L	5	EPA 8270	02-Mar-18/K	< 5	< 5	100	IMAC
Diclofop-methyl	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5	< 0.5	9	MAC
Dimethoate	µg/L	1	EPA 8270	02-Mar-18/K	< 1	< 1	20	IMAC
Diquat	µg/L	5	EPA 549.1	22-Feb-18/K	< 5	< 5	70	MAC
Diuron	µg/L	5	EPA 8270	02-Mar-18/K	< 5	< 5	150	MAC
Glyphosate	µg/L	25	EPA 547	22-Feb-18/K	< 25	< 25	280	IMAC
Malathion	µg/L	5	EPA 8270	02-Mar-18/K	< 5	< 5	190	MAC
Metolachlor	µg/L	3	EPA 8270	02-Mar-18/K	< 3	< 3	50	IMAC
Metribuzin	µg/L	3	EPA 8270	02-Mar-18/K	< 3	< 3	80	MAC
Paraquat	µg/L	1	EPA 549.1	22-Feb-18/K	< 1	< 1	10	IMAC
Pentachlorophenol	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1	< 0.1	30,60	AO,MAC
Phorate	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3	< 0.3	2	IMAC
Picloram	µg/L	5	EPA 8270	02-Mar-18/K	< 5	< 5	190	IMAC
Poly-Chlorinated Biphenyls (PCB's)	µg/L	0.05	EPA 8082	20-Feb-18/K	< 0.05	< 0.05	3	IMAC
Prometryne	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1	< 0.1	1	IMAC
Simazine	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5	< 0.5	10	IMAC
Terbufos	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3	< 0.3	1	IMAC
Tetrachlorophenol, 2,3,4,6-	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1	< 0.1	1,100	AO,MAC
Triallate	µg/L	10	EPA 8270	02-Mar-18/K	< 10	< 10	230	MAC
Trichlorophenol 2,4,6-	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1	< 0.1	2,5	AO,MAC
Trifluralin	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5	< 0.5	45	IMAC
MCPA	µg/L	10	EPA 8151A	01-Mar-18/K	< 10	< 10	0.1	MAC

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: DWC180213S

REPORT No. B18-03847

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 13-Feb-18

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 05-Mar-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed	ST # 1 Treated	ST # 2 Treated	ODWS	
							Objective	Type of Objective
Free Chlorine	mg/L		n/a	13-Feb-18/B	0.84	0.95		

1. Free chlorine results provided by client.

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

C.O.C.: DW180213S

REPORT No. B18-03847

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 13-Feb-18

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 05-Mar-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

<b>Client I.D.:</b>	ST # 3 Treated		<b>ODWS</b>	
<b>Sample I.D.:</b>	B18-03847-3		<b>Objective</b>	<b>Type of Objective</b>
<b>Date Collected:</b>	12-Feb-18			

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Benzene	µg/L	0.5	EPA 8260	14-Feb-18/O	< 0.5		1	MAC
Carbon Tetrachloride	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2		2	MAC
Dichlorobenzene,1,2-	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1		3,200	AO,MAC
Dichlorobenzene,1,4-	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2		1,5	AO,MAC
Dichloroethane,1,2-	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1		5	IMAC
Dichloroethene, 1,1-	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1		14	MAC
Dichloromethane (Methylene Chloride)	µg/L	0.3	EPA 8260	14-Feb-18/O	< 0.3		50	MAC
Monochlorobenzene (Chlorobenzene)	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2		80	MAC
Tetrachloroethylene	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2		10	MAC
Trichloroethylene	µg/L	0.1	EPA 8260	14-Feb-18/O	< 0.1		5	MAC
Vinyl Chloride	µg/L	0.2	EPA 8260	14-Feb-18/O	< 0.2		1	MAC
Alachlor	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3		5	IMAC
Atrazine + Metabolites	µg/L	0.5	Calc.	02-Mar-18/K	< 0.5		5	IMAC
Azinphos-methyl	µg/L	1	EPA 8270	02-Mar-18/K	< 1		20	MAC
Benzo(a)pyrene	µg/L	0.005	EPA 8270	02-Mar-18/K	< 0.005		0.01	MAC
Bromoxynil	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3		5	IMAC
Carbaryl	µg/L	3	EPA 8270	02-Mar-18/K	< 3		90	MAC
Carbofuran	µg/L	1	EPA 8270	02-Mar-18/K	< 1		90	MAC
Chlorpyrifos	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5		90	MAC
Diazinon	µg/L	1	EPA 8270	02-Mar-18/K	< 1		20	MAC
Dicamba	µg/L	5	EPA 8270	02-Mar-18/K	< 5		120	MAC
Dichlorophenol, 2,4-	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1		0.3,900	AO,MAC

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: DW180213S

REPORT No. B18-03847

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 13-Feb-18

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 05-Mar-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

<b>Client I.D.:</b>	ST # 3 Treated	<b>ODWS</b>
<b>Sample I.D.:</b>	B18-03847-3	
<b>Date Collected:</b>	12-Feb-18	
		<b>Objective</b>
		<b>Type of Objective</b>

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed				
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	µg/L	5	EPA 8270	02-Mar-18/K	< 5		100	IMAC
Diclofop-methyl	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5		9	MAC
Dimethoate	µg/L	1	EPA 8270	02-Mar-18/K	< 1		20	IMAC
Diquat	µg/L	5	EPA 549.1	22-Feb-18/K	< 5		70	MAC
Diuron	µg/L	5	EPA 8270	02-Mar-18/K	< 5		150	MAC
Glyphosate	µg/L	25	EPA 547	22-Feb-18/K	< 25		280	IMAC
Malathion	µg/L	5	EPA 8270	02-Mar-18/K	< 5		190	MAC
Metolachlor	µg/L	3	EPA 8270	02-Mar-18/K	< 3		50	IMAC
Metribuzin	µg/L	3	EPA 8270	02-Mar-18/K	< 3		80	MAC
Paraquat	µg/L	1	EPA 549.1	22-Feb-18/K	< 1		10	IMAC
Pentachlorophenol	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1		30,60	AO,MAC
Phorate	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3		2	IMAC
Picloram	µg/L	5	EPA 8270	02-Mar-18/K	< 5		190	IMAC
Poly-Chlorinated Biphenyls (PCB's)	µg/L	0.05	EPA 8082	20-Feb-18/K	< 0.05		3	IMAC
Prometryne	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1		1	IMAC
Simazine	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5		10	IMAC
Terbufos	µg/L	0.3	EPA 8270	02-Mar-18/K	< 0.3		1	IMAC
Tetrachlorophenol, 2,3,4,6-	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1		1,100	AO,MAC
Triallate	µg/L	10	EPA 8270	02-Mar-18/K	< 10		230	MAC
Trichlorophenol 2,4,6-	µg/L	0.1	EPA 8270	02-Mar-18/K	< 0.1		2,5	AO,MAC
Trifluralin	µg/L	0.5	EPA 8270	02-Mar-18/K	< 0.5		45	IMAC
MCPA	µg/L	10	EPA 8151A	01-Mar-18/K	< 10		0.1	MAC

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: DW180213S

REPORT No. B18-03847

**Report To:**

**Clearview, Township of**  
 217 Gideon Street, Box 200  
 Stayner Ontario L0M 1S0 Canada

**Attention:** Todd Patton

**Caduceon Environmental Laboratories**

112 Commerce Park Drive  
 Barrie ON L4N 8W8  
 Tel: 705-252-5743  
 Fax: 705-252-5746

DATE RECEIVED: 13-Feb-18

JOB/PROJECT NO.: Stayner W.S.

DATE REPORTED: 05-Mar-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO. 220001138

Parameter	Units	R.L.	Reference Method	Date/Site Analyzed	Result	ODWS	
						Objective	Type of Objective
Free Chlorine	mg/L		n/a	13-Feb-18/B	0.95		

1. Free chlorine results provided by client.

ODWS - Ontario Drinking Water Standards  
 AO - Aesthetic Objectives  
 IMAC - Interim Maximum Acceptable Concentration  
 MAC - Maximum Acceptable Concentration  
 OG - Operational Guidelines

R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an \*

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie



Christine Burke  
 Lab Manager